



The Corporation of the Town of Ingersoll & the County of Oxford

1-2024 Raglan Street Reconstruction

ADDENDUM NO. 1

1. Acknowledgement of Addendum

Please insert the Acknowledgement of Addendum with the completed tender and ensure that all parts have been completed.

2. Questions and Answers

- i) **Town of Ingersoll specs – the link found at the bottom of Page C-1 is a broken link.**

Please follow this link for the Town of Ingersoll Design Guidelines and Specifications for Municipal Works:

https://www.ingersoll.ca/en/live-and-play/resources/Engineering-Services/Town-Standards_Draft215_r.pdf

- ii) **Page 3 [Page A-2] of the tender document stipulates 60 working day acceptance period for the bid bond. Could you please clarify if a 60 day acceptance period is intended, or if you require a 90 day acceptance period?**

A 60 day acceptance period is intended.

- iii) **Does the Town have chemical testing of the soil to be excavated?**

The Contractor is to assume that the excavated material is suitable for reuse and the material is not to be removed from site. However, if it is determined that the excavated material is contaminated, the Town will

pay for removal under Additional Unit Price #8. All material testing will be paid for by the Town.

- iv) **Special Provisions Item E103 calls for Granular 'B' Type II – is Oxford County Spec. Granular 'B' acceptable?**

The Contractor is directed to supply and place Granular 'B' Type II in accordance with OPSS.MUNI 1010 and with the Tender Documents.



**The Corporation of the Town of Ingersoll
& the County of Oxford**

**1-2024
Raglan Street Reconstruction**

ACKNOWLEDGEMENT OF ADDENDA

I/We hereby acknowledge receipt of Addenda No. 1 to _____ and certify this Tender has been prepared in accordance with the terms of the Addenda.

Signature and Seal of Contractor

Witness

Office of Person Signing for Contractor

Dated: _____, 2024.